

# BusWorks® 900EN Series – Modbus TCP/IP 10/100M Industrial Ethernet I/O Modules

Model 966EN-4004 Four Channel RTD Input Module Model 966EN-4006 Six Channel RTD Input Module

## **USER'S MANUAL**



ACROMAG INCORPORATED 30765 South Wixom Road Wixom, MI 48393-2417 U.S.A.

Tel: (248) 295-0880 Fax: (248) 624-9234

## **TABLE OF CONTENTS**

Symbols on equipment:



Means "Refer to User's Manual (this manual) for additional information".
The information of this manual may change without notice. Acromag makes no warranty of any kind with regard to this material, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose. Further, Acromag assumes no responsibility for any errors that may appear in this manual and makes no commitment to update, or keep current, the information contained in this manual. No part of this manual may be copied or reproduced in any form without the prior written consent of Acromag, Inc.

For additional information, please visit our web site at www.acromag.com and download our whitepaper 8500-765, Introduction To Modbus TCP/IP. or 8500-648. Introduction to Modbus.

Windows® is a registered trademark of Microsoft Corporation.

#### IMPORTANT SAFETY CONSIDERATIONS


You must consider the possible negative effects of power, wiring, component, sensor, or software failure in the design of any type of control or monitoring system. This is very important where property loss or human life is involved. It is important that you perform satisfactory overall system design and it is agreed between you and Acromag, that this is your responsibility.

## **GETTING STARTED**


MOUNTING AND DIMENSIONS	3
CONTROLS & INDICATORS	3
ISOLATION BARRIERS	3
CONNECTIONS	4
DIN-Rail Mounting And Removal	4
Network	4
Power	6
Analog Inputs	6
Earth Ground	6
WEB BROWSER	7
Home Page	7
Password Configuration Page	8
Network Configuration Page	8
I/O Mapping Page (Optional i2o Function)	10
Test Page	12
Calibration Page	13
Input Calibration	15
TROUBLESHOOTING	16
Diagnostics Table	16
Trouble Browsing Your Module?	17
Getting Out Of Trouble	17

#### TEC


CHNICAL REFERENCE	
KEY FEATURES	18
HOW IT WORKS	19
ABOUT MODBUS TCP/IP	20
IP Addressing	20
Dynamic Host Configuration Protocol	22
Domain Name System (DNS)	22
MODBUS REGISTERS	22
Register Functions	22
Register Mirroring	23
Data Types	24
Register Map	25
SPECIFICATIONS	35
Model Numbers	35
Analog Inputs	35
General Specifications	36
Enclosure and Physical	36
Agency Approvals	37
Environmental	37
Ethernet Interface	38
Controls & Indicators	39
ACCESSORY CABLES	39
REVISION HISTORY	42



#### MODEL 966EN ENCLOSURE DIMENSIONS



The toggle switch is used to toggle the module into or out of Default Mode (toggle left), or to reset the module (toggle right). In Default Communication Mode, the yellow ST LED blinks slowly and the module assumes a fixed static IP address of "128.1.1.100", a default subnet mask of "255.255.255.0", a default username of "User", and a default password of "password00".



## MOUNTING AND DIMENSIONS

Unit mounts to "T" type DIN rails (35mm, type EN50022).

Units may be mounted sideby-side on 1-inch centers.

WARNING: IEC Safety Standards may require that this device be mounted within an approved metal enclosure or sub-system, particularly for applications with exposure to voltages greater than or equal to 75VDC or 50VAC.

## CONTROLS & INDICATORS

Green Run LED is ON if power is on and will blink in "wink" ID mode.

Yellow ST LED blinks ON/OFF if module is in default mode and stays ON if an input is out of range.

Green LINK LED is ON if autonegotiation has successfully established a connection.

Yellow ACT LED signals PHY network Activity (busy).

#### **ISOLATION BARRIERS**

Dashed Lines denote isolation barriers.


The input circuit, network, and power circuit are isolated from each other for safety and noise immunity.



## CONNECTIONS

## DIN-Rail Mounting & Removal

When attaching the module to the T-type DIN rail, angle the top of the unit towards the rail and locate the top groove of the adapter over the upper lip of the rail. Firmly push the unit towards the rail until it snaps into place. To remove, first separate the input terminal block(s) from the bottom side of the module to create a clearance to the DIN mounting area. Next, while holding the module in place from above, insert a screwdriver into the lower arm of the DIN rail connector and use it as a lever to force the connector down until the unit disengages from the rail (do not twist the screwdriver to avoid damaging plastic).



#### Network

For 100Base-TX systems, use data grade Unshielded Twisted-Pair (UTP) wiring that has a 100Ω characteristic impedance and meets the EIA/TIA Category Five wire specifications.

It is recommended that you use a crossover CAT-5 cable to connect this device to your PC.

For 10Base-T systems, you may use Category 3, Category 4, or Category 5 UTP cable.


In either case, you are limited to 100 meters between any two devices.

A crossover cable simply connects the differential transmit pair on each end, to the receive pair on the opposite end.

Use a standard (direct) cable when connecting to a hub or switch port, which are generally wired MDI-X.

#### RJ45 MDI AND MDI-X CONNECTIONS

PIN	MDI WIRING	MDI-X WIRING
1	Transmit + \	/ Receive +
2	Transmit -	Receive -
3	Receive +	Transmit +
4	Not Used	Not Used
5	Not Used /	Not Used
6	Receive -	Transmit -
7	Not Used	Not Used
8	Not Used	Not Used




Note Crossover Connections

#### MNIMUMRECOMMENDED CABLE

SPEED	DISTANCE	CABLE
10Base-T	100M	CAT 3, CAT 4, or CAT 5 UTP/STP
100Base-T 100M CAT 5/5e UTP/STP		CAT 5/5e UTP/STP

The Ethernet port of this module is wired MDI and does not include automatic crossover. The Ethernet port of your PC is also wired MDI and may not include automatic crossover. As such, you must use a crossover cable like that shown below when connecting this device directly to a PC.




Refer to the section "Cable Accessories" at the back of this manual for more information on accessory cables including patch and crossover cables available from Acromag and other vendors.


**TIP:** You can significantly enhance the EMI/RFI performance of your network connections by using Category 5E STP cable (Shielded Twisted Pair) with shielded RJ45 plug connectors. This will also help to protect your installation from damage due to ESD (Electro-Static Discharge). The use of shielded cable is strongly recommended for installations in harsh industrial environments and/or in the presence of strong electrical fields.

## CONNECTIONS

#### Network



You can use an Ethernet switch or switching hub to build a network of Ethernet modules, similar to that shown below. This drawing shows how to network-connect these modules to a 5-port Ethernet switch (Acromag Model 900EN-S005). Note that the 900EN-S005 switch includes automatic MDI/MDI-X crossover and straight-through or crossover cable(s) may be used, but it is generally not good practice to use crossover cables when connecting to the switch.





## CONNECTIONS

#### **Power**

Voltage	Current
15VDC	125mA
18VDC	105mA
24VDC	80mA
36VDC	59mA

**CAUTION:** Risk of Electric Shock – More than one disconnect switch may be required to de-energize this equipment before servicing.

#### **Analog Inputs**

Input is Cu, Pt, or Ni RTD, or linear resistance, connected in 2-wire, or 3-wire fashion.

Inputs are not isolated channel-to-channel.

Unused inputs should be terminated and not left floating.

For 2-wire connections, be sure to jumper the IN- and INL leads together.


Do NOT attach earth ground to any input leads. Earth ground should instead be connected to the GND terminal at TB3-33.

#### **Earth Ground**

Warning: To comply with safety and performance standards, use shielded cable and connect earth ground as noted. Failure to use good wiring and grounding practices may be unsafe and hurt performance.

✓ Connect 15-36V DC to the power terminals labeled DC+ & DC-.


Observe proper polarity. For supply connections, use No. 14 AWG wires rated for at least 75°C. **CAUTION:** Do not exceed 36VDC peak.



Note that earth ground is connected to the GND terminal as shown at left and is not connected to the inputs.


**IMPORTANT – External Fuse:** If unit is powered from a supply capable of delivering more than 1A to the unit, it is recommended that this current be limited via a high surge tolerant fuse rated for a maximum current of 1A or less (for example, see Bel Fuse MJS1).


Connect analog input signals to the input terminals as shown below according to your model. **Note earth ground**.



NOTE 1: DO NOT APPLY EARTH GROUND TO INPUT LEADS OR INPUT TERMINALS. EARTH GROUND SHOULD INSTEAD BE APPLIED AT THE INPUT LOGIC GROUND TERMINAL (GND AT TB3-33).

IMPORTANT: RTD INPUTS ARE NOT ISOLATED CHANNEL TO CHANNEL






Connect Earth Ground as shown in the connection drawings above.
 Additionally, connect the GND terminal (TB3-33) to earth ground.

The ground connections noted are recommended for best results. If sensors are already grounded, use caution and avoid making additional ground connections which could create ground loops.

The plastic module housing does not require earth ground.

This module supports Modbus over TCP/IP. You may use your own software to issue Modbus command to this module (see Modbus Registers), or you may use a web browser to achieve basic functionality, as the 966EN modules have built-in web pages that allow you to setup, control/test, and calibrate the module. Simply execute your web browser, type the IP address assigned to your module in the "Address" window (<a href="http://128.1.1.100/">http://128.1.1.100/</a> for our example), click [Go], and you will be presented with a Home Page window similar to that shown below:



The Home Page provides buttons to access the other web pages of this module that are used to configure network parameters, change the user name and password, calibrate the module, map inputs to outputs, and operate/test the module.

For each new browser session that accesses the Home Page of this module, you will be presented with a window prompting you to enter the current User Name and Password as shown below. This information is required before the program will allow you to make any other selections. 
The default user name and password is "User" and "password00" respectively. After entering the defaults, you may wish to invoke the Password Configuration Page to change these parameters to something more meaningful to you. Note that these entries are case-sensitive.



IMPORTANT: If you forget your user name & password, you can always toggle the module into default mode via the default mode toggle switch at the front of the module. Then the password and username will revert to the original defaults noted above, allowing you to re-invoke the Password Configuration Page and change the username and password settings as required.

## **WEB BROWSER**


**Home Page** 

## **WEB BROWSER**

## Password Configuration Page

Use up to 20 alphanumeric characters (case sensitive) to specify your username, and 10 alphanumeric characters (case sensitive) to specify a password. You will have to type in these entries twice to help prevent errors (yes, I know this is annoying).


Click the **submit** button to write your changes to the module.



After completing your username/password changes, click on the appropriate button at the bottom of the page to select another web page. If you made changes, you may be prompted to re-enter your new username and password before being permitted to move to other pages.

## **Network Configuration**

After setting your username and password, you can click the "Network Configuration Page" button to set the network configuration parameters for the module. You may have to consult your network administrator for help to complete the contents of this page.





An **IP Address** is a unique identification number for any host (this module) on any TCP/IP network (including the internet). The IP address is made up of four octets (8 bits), each octet having a value between 0-255 (00H-FFH). It is expressed here in decimal form, with a period placed between octets.

A **Static IP Address** is as the name implies—*static*, and represents a unique fixed IP Address that is generally assigned by your service provider or system administrator. The default static IP address assigned to this module from the factory is 128.1.1.100 (refer to product side label).

**NOTE:** In order to network your PC with an Acromag module, you may have to consult with your network administrator and either temporarily change your TCP/IP configuration (see TCP/IP Properties of Network Configuration in Windows), or create a separate private network using a second network adapter installed in your PC (recommended). The necessary steps will vary with your operating system. Refer to Acromag Application Note 8500-734 to help accomplish this (located on the CDROM shipped with your module or via download from our web site at www.acromag.com).

The **Number of Sockets** refers to the number (1-10) of Modbus TCP/IP access points to allow for this host. The default allows up to 10 sockets, but you can restrict access by reducing this number. Internally, the module uses port number 502, which is reserved for Modbus.

The **DNS Server** refers to the IP address of the Domain Name Server used on this network. A DNS server relates symbolic names to actual IP addresses, while the DHCP server is responsible for dynamically passing out IP addresses.

A **Subnet Mask** is used to subdivide the host portion of the IP address into two or more subnets. The subnet mask will flag the bits of the IP address that belong to the network address, and the remaining bits correspond to the host portion of the address. The unique subnet to which an IP address refers to is recovered by performing a bitwise AND operation between the IP address and the mask itself, with the result being the sub-network address.

**Gateway** refers to the IP Address of the gateway, if your local area network happens to be isolated by a gateway. Typically, it is assigned the first host address in the subnet. If a gateway is not present, then this field should contain an unused address within the host subnet address range.

The **Host Name** is the name to be assigned to this host if its address happens to be assigned dynamically using DHCP.

The **Active IP Address** refers to the current IP Address being used by this host, as opposed to any new assignments being made via this page.

The **MAC** Address refers to the Media Access Control Address that uniquely identifies the hardware of this device. This is a unique fixed address assigned to this module at the factory. On IEEE 802 networks, the Data Link Control (DLC) layer of the OSI Reference Model is divided into two sublayers: the Logical Link Control (LLC) layer, and the Media Access Control (MAC) layer. The MAC layer interfaces directly with the network media (each different type of network media requires a different MAC layer).

## **WEB BROWSER**

#### **Network Configuration**

Note that Acromag Series 9xxEN Ethernet I/O modules may take from 3-30 seconds to boot upon power-up, depending on your network configuration and whether a DHCP server is present.

This module can be placed into a default communication mode via the DFT toggle switch at the front of the module.

Default Mode uses a static IP address of "128.1.1.100", a default subnet mask of "255.255.255.0", a default username "User", and a default password "password00".

## **WEB BROWSER**

## **Network Configuration**

By default, the module is setup to use **Static IP Addressing and a Static IP Address of 128.1.1.100**. You can optionally choose to have the IP address assigned dynamically via DHCP/BOOTP or DHCP/BOOTP w/Fallback. This will also require that you specify a valid Host Name. Note that DHCP/BOOTP w/Fallback will revert to the static IP address if your DHCP or BOOTP server cannot be found at the address specified.

In general, BOOTP (Bootstrap Protocol) refers to an internet protocol that enables a diskless workstation to discover its own IP address, the address of a BOOTP server on the network, and a file to be loaded into memory to boot the machine. This enables the workstation or device server to boot without requiring a hard or floppy disk drive. BOOTP works similar to DHCP, but is usually found in older systems. This protocol is defined by RFC 951.

DHCP (Dynamic Host Configuration Protocol) refers to a protocol for assigning dynamic IP addresses to devices on a network. With dynamic addressing, a device can have a different IP address every time it connects to the network. In some systems, it can even change while it is still connected. DHCP also supports a combination of static and dynamic IP addresses. DHCP/BOOTP with fallback will revert to static IP addressing if the DHCP or BOOTP server cannot be found.

The unit includes a default address toggle switch to cause the module to assume a fixed default static IP address (128.1.1.100). This switch is at the front of the module and is used to toggle the module into, or out of Default Mode. If you use the toggle switch at the front of the module to place the module in default mode, then "Default Communications Mode" will be indicated at the bottom of this screen.

Click the **Submit** button to complete any changes made on this page

Click the **Wink On/Off** button to toggle the module in/out of "wink" ID mode. In this mode, the module's green RUN LED will blink to confirm identification as an aide to locating a specific module on a network.

Refer to the Technical Reference section of this manual to learn more about IP Addressing terms and concepts.


## I/O Mapping Page (Optional i2o Function)

This module includes special messaging functionality (i2o, input-to-output communication) that allows it to send its input level to an output channel on an Acromag 972EN-400x or 973EN-400x analog output module. The I/O Mapping page is used to specify the static IP address of the 972/973EN module to send input data to, the specific Holding Register address of that module (which channel), an update rate, and to set the scaling.



**IMPORTANT:** This module is designed to function as a Modbus TCP/IP slave/server. Normally, Modbus servers are not allowed to initiate messages on their own and may only respond to client/master requests. The I/O mapping function is a special application that may cause confusion for master/client devices linked to the same network. Other master devices should be restricted from attempting to control i2o target devices.

Each input channel of this device may be mapped to one or two output channels of Acromag 972EN-400x (current output), or 973EN-400x (voltage output) modules. The output channel that is to be controlled in this manner is determined by the Map-To Holding Register address specified. The data written will be scaled to percent-of-span units. Subsequent messages will be sent at a periodic rate specified via the update time. Note that the target output channels may still be controlled independently, but their level will be overwritten by subsequent mapped messages when enabled.



You can map each input channel to one or two analog output channels of another 972EN or 973EN module. The Map To Holding Register determines the output channel it will map to. Since the input signal is in wide-range engineering units, you must also specify the scaling between the input units and 0-100% at the output channel.

**<u>Update Time:</u>** Specify a time from 0-90 seconds between messages. Specify 0 to turn mapped messaging OFF.

<u>Map To IP Address:</u> This is the Static IP Address of the target output device (a 972/973EN module on the network).

Map To Holding Register Address: Specify a valid 4xxxx holding register address in the target device for writing to the output. For the 972/973EN, only addresses 40019 to 40024 will apply and correspond to channels 0-5. Input Scaling: Since the input signal is in engineering units and widerange, you must select which portion of the input range will map to 0% and 100% at the output.

## **WEB BROWSER**

## I/O Mapping Page (Optional i2o Function)

This messaging function works best if the target module(s) are already online and ready to receive messages. It will still work if the target output modules come online after the input module, but may take several minutes to "discover" all the network targets and begin transmitting to them.

If the input module or the target module(s) go offline, remote messaging will resume on its own when the connection is re-established, but this "healing" function may take several minutes depending on which device(s) went offline, why, and for how long.

**Note:** Remote messaging may only be configured via the built-in web browser page as there are no Modbus registers for specifying these parameters.

The actual data written to the analog output is rescaled to percent-of-span units (a 16-bit signed integer value with resolution of 0.005%/lsb). For example, -100%, 0% & +100% output will be represented by the decimal values –20000, 0, and 20000, respectively.

## **WEB BROWSER**


## **Test Page**


TIP: Viewing a module's web page is treated similar to viewing a web page on the internet. The first time you open a page, its image is stored as a temporary internet file in PC memory. However, each subsequent attempt to view that page will need to automatically update that image, especially when making configuration changes. With Internet Explorer, click the "Internet Options" of the "Tools" menu, select the "General" tab, locate the "Temporary Internet Files" information and click on the "Settings" button. Then select "Automatically" under "Check for newer versions of stored pages:". Then click [OK] to return to the "General" screen, and click [OK] again to save your settings.

Use the scroll bar on the right to scroll down the page as shown at left.

Note that the 4 or 6 channels of these modules are divided into 2 or 3 pairs of channels (ports). Channels of the same port must share the same input range configuration, but the configuration may vary between the three ports.

After completing your username/password assignment, plus your network configuration, you can use the Test Page to operate your module. The Test Page will allow you to read inputs, change input ranges, and set the lead break detect direction for this model.






**IMPORTANT:** The input signal indicated only reflects the level of the inputs at the moment this screen is invoked and this does not continuously update. You can click your browser's refresh button to get a new input update.

You can also use the Configuration Control of this page to change the input range for each port or channel pair (0/1, 2/3, or 4/5). For the 966EN shown, you may select from 5 ranges in 2-wire and 3-wire configurations. Note that your range selection will apply to both channels of the port. Click on "submit" to execute your range change.

**Note (Lead Break):** Internally, RTD values are represented via 16-bit signed integers with a resolution of 0.1°C/lsb and a possible range of – 3276.8°C to +3276.7°C. As such, a count of 0-7FFFH is a positive number, while 8000-FFFFH is a negative number. However, the upscale/downscale break counts are trimmed to a reasonable range value according to the RTD type. The downscale (break) detent is 63105 (Pt385), 63141 (Pt391), 63715 (Ni), and 63281 (Cu). The upscale break detent is 12618 (Pt385), 12421 (Pt391), 3455 (Ni), and 32767 (Cu).

The Calibration Page will allow you to recalibrate each channel's zero and span signal as required. Simply select the channel to be calibrated, choose zero or span, apply the zero or full-scale signal to the input, then click calibrate. For best results, always calibrate zero before span.



Note that if calibration has been done improperly at any input, you may click on the **Restore Factory Calibration** button to return the module to its original factory calibration for <u>all</u> channels.

Use the scroll bar on the right to scroll down the page as shown below:

## **WEB BROWSER**


## **Test Page**

## **Calibration Page**

IMPORTANT: This module has already been calibrated at the factory and recalibration is not normally required, except as necessary to correct for long term component aging, or to satisfy your company's maintenance requirements. Do not attempt to recalibrate this module unless absolutely required, as miscalibration will negatively affect the module's performance.

## **WEB BROWSER**

## **Calibration Page**



If recalibration of any input is required, all applicable ranges should be done. The following table gives the calibration values for the input ranges of these models. These are the specific input signals required to calibrate the range endpoints.

Your success in recalibrating the input will strongly depend upon the accuracy and precision of your signal source.

For the 966EN, when you calibrate the 0-500 ohm range, the Pt385, Pt391, and Nickel ranges are automatically interpolated and calibrated at the same time (their ideal calibration points are shown in the table for reference). The Copper range must be calibrated separately.

INPUT RANGE	LO Calibration	HI Calibration
Cu 10Ω (-200 to +260°C), α=1.4272	0°C (9.04Ω)	250°C (18.73Ω)
0-500Ω Linear Resistance, α=1.000	10.00Ω	450.00Ω
Pt 100Ω (-200 to +850°C), $\alpha$ =1.3850	<del>0°C (100Ω)</del>	<del>850°C (390.48Ω)</del>
Pt 100Ω (-200 to +850°C), α=1.3911	<del>0°C (100Ω)</del>	<del>850°C (395.12Ω)</del>
Ni 120Ω (-80 to +320°C), α=1.6720	<del>0°C (120Ω)</del>	<del>300°C (439.44Ω)</del>

Note: The platinum and nickel calibration points are derived from the 0-500  $\!\Omega$  range endpoints.

**IMPORTANT:** For best results, be sure to use a precision resistance source or RTD calibrator capable of reproducing nominal endpoint signals at least as accurate as the module itself (better than ±0.1% of span). Select 2-wire or 3-wire according to your final application. Further, allow the module to warm up a few minutes prior to calibration.

15

The unit supports separate calibration for both 3-wire and 2-wire configurations. Calibrate the unit using the wiring configuration required by your application.

## <u>Method 1 – Calibration Using The Built-In Browser Interface</u>:

- 1. Make sure that the range that needs calibrating is currently selected.
- 2. Bring up browser interface and select calibration page.
- 3. Apply either the zero or span input signal to the channel to be calibrated. Calibrate the zero endpoint signal first, the span endpoint signal second.
- 4. Wait about 10 seconds for the input to settle and be read.
- 5. Click on the channel number and select either zero or span calibration.
- 6. Click on the "Calibrate" button. The page will refresh and calibration may continue. Repeat this process for the other endpoint (span).
- 7. Repeat steps 2-5 for the other input channels to be calibrated.
- 8. Repeat steps 1-7 for the other input ranges, as required.

#### Method 2 - Calibration Via The Modbus TCP/IP Interface:

- 1. Write to the appropriate Port Input Range Register to select the input range to be calibrated for your channel(s) of interest.
- 2. Write 24106 (5E2AH) into the Calibration Access Register to remove write protection from the calibration registers.
- 3. Apply the zero calibration signal (Cal Lo, see table) to the input to be calibrated and allow the input to settle about 10 seconds.
- 4. Write a 16-bit value to the Zero Calibration Register with a set bit in the bit position that corresponds to the channel number to be calibrated (one channel at a time). If you were calibrating the zero of channel 5, you would write 0x0010 to the Zero Calibration Register. The module will replace calibration coefficients immediately, no reset needed.
- 5. Apply the full-scale calibration signal (Cal Hi, see table) to the input to be calibrated and allow the input to settle about 10 seconds.
- 6. Write a 16-bit value to the Span Calibration Register with a set bit in the bit position that corresponds to the channel number of the channel to be calibrated (one channel at a time). For example, if you wanted to calibrate the span of channel 0, write 0x0001 to the "Span Cal Register".
- 7. Write to the Port Input Range Register to select the next range to be calibrated for this channel. Repeat steps 3-6 for the next range as required.
- 8. Repeat steps 3-7 for the other channels as required.
- 9. When finished calibrating, write 0x0000 to the Calibration Access Register (Holding register 21) to replace write protection to the calibration registers and prevent miscalibration.

#### **WEB BROWSER**

## **Input Calibration**

You can choose to use the web browser calibration page to accomplish calibration as described at right in Method 1 (easiest), or via direct register access using your own software as described in Method 2.

## TROUBLE-SHOOTING

## **Diagnostics Table**

Upon power-up, the green RUN LED should light. A continuous blinking Run LED indicates "wink" ID mode. If the Run LED remains OFF and correct power has been applied, then either the internal power supply has failed or a fatal processor error (firmware) has occurred.

SYMPTOM	POSSIBLE CAUSE	POSSIBLE FIX
Green RUN LED does not light.	Internal +3.3V power has failed.	Return module for repair.
Continuous flashing green RUN LED.	Module in "wink" mode.	Read Module Status register to verify "wink" status. Write 5555H to Wink Mode Toggle Register to toggle wink mode off/on.
Cannot communicate.	Power ON at the module?	Check power. Is green RUN LED ON?
	Connecting cable is not a crossover cable.	This module's Ethernet port is wired MDI. You must use a crossover cable when
	TIP: To check cable type, hold both ends in same position and read the wire colors through the clear portion of the plug from left to right. If colors are arranged in the same order, you have a straight cable.	connecting this module to your PC or another device also wired MDI. If you are connecting to an Ethernet switch or hub, then a direct cable is used.  Note: If your Link LED is ON, you have connected using the correct type of cable, but it could still be defective.
	Wrong IP Address	Change the IP address of the module or the PC so that both match. Try the default module address of 128.1.1.100. For the PC NIC, try another node address.
Many Communication Errors.	Is cable segment longer than 100M?	Maximum distance between two nodes is limited to 100 meters using approved cable.
	Correct Cable?	Shielded CAT-5/5E cable or equivalent is recommended.
	Missing earth ground connection.	Connect earth ground to TB3-33 GND terminal adjacent to power terminal.
Cannot Browse Module.	Your browser may be setup to use a proxy server for LAN communications.	Temporarily disable the use of a proxy server by your browser (see procedure of next page).

If your problem still exists after checking your wiring and reviewing this information, or if other evidence points to another problem with the unit, an effective and convenient fault diagnosis method is to exchange the module with a known good unit. Acromag's Application Engineers can provide further technical assistance if required. Complete repair services are also available from Acromag.

17

Please refer Acromag Application Note 8500-734 for help in setting up network communication with your module (located on the CDROM shipped with your module or via download from our web site at <a href="www.acromag.com">www.acromag.com</a>). This document gives details for changing your PC's TCP/IP configuration in order to communicate with your module (see TCP/IP Properties of Network Configuration in Windows).

If you have carefully followed this procedure and you still cannot browse your module, you may have the web browser of your laptop or PC setup to use a proxy server when browsing the web. If you are using Internet Explorer, Refer to the "Tools" pulldown menu, select "Internet options...", click the "Connections" tab, then click the "LAN Settings" button. Locate the Proxy server information and uncheck the box next to the statement "Use a proxy server for your LAN". Then click [OK] to return to the "Connections" screen, and click [OK] again to save your settings.

You should now be able to use Internet Explorer to browse the module as required. However, to later restore your PC's connection to your company network, you may have to re-enable the use of a proxy server for your LAN.

There is no built-in error detection to prevent you from writing invalid values to a configuration register. As such, if you inadvertently write an invalid value to an internal register, you could cause the module to become inoperable under certain conditions. If this happens, in order to regain control of the module, the module can either be re-downloaded at the factory, or you can try restoring the module to its initial configuration by following this procedure:

#### Procedure For Restoring any 9xxEN Module to its Initial Configuration

- 1. While module power is OFF, press and hold the front-panel toggle switch in the default (DFT left) position.
- 2. While continuing to hold the toggle switch in the default position, apply power to the module.
- 3. After a few seconds, the Status LED will begin to blink quickly and you can release the default switch at this point. The module will continue to boot itself as it normally does. That is, the green RUN LED will blink for 1-10 seconds as the unit acquires its address, then remain ON for normal operation.
- 4. If the STATUS LED fails to blink rapidly after a few seconds and the RUN LED just blinks for a few moments as it normally does, then reinitializing the module has failed and you should try it again. This time, make sure that the DFT switch is completely depressed and held while powering the unit. Also make sure that you are pressing the DFT toggle in the DFT direction (left), rather than the RST direction (right).

## TROUBLE-SHOOTING

Trouble Browsing Your Module?

## **Getting Out Of Trouble**

So, your module's "gone wild", follow this procedure to restore it to its initial configuration and regain control.

## **TECHNICAL REFERENCE**


#### **KEY FEATURES**

- Safety Agency Approvals CE, UL, & cUL listed, plus Class I; Division 2; Groups A, B, C, D approval.
- Fully Isolated Input channels (as a group), network, and power are all isolated from each other for safety and increased noise immunity.
- Modbus TCP/IP Protocol Support Supports up to 10 master sockets (maximum number is user-selectable) using port number 502 (Modbus TCP/IP Default).
- I/O Mapping (i2o) Feature Allows the analog inputs of these models to map their values to the analog outputs of 972EN-4006 or 973EN-4006 modules on the network.
- **Built-In Web Pages** Allows unit to optionally be configured, controlled, calibrated, and monitored via a standard web browser over Ethernet.
- Convenient "Wink" ID Mode Support Blinks green RUN LED in wink mode as a visual tool to help identify specific remote units on a network.
- Fully Independent w/ Direct I/O Connection Self-contained with no special bus couplers, power supply, or rack mount required to operate.
- **Isolated Network Interface** Immune to noise & can operate over long distances. Allows many modules to network together. RJ45 port includes transient protection from ESD, EFT, and other transients.
- 10Base-T and 100Base-TX Support Integrated IEEE 802.3/802.3u 100Base-TX/10Base-T.
- Auto-Negotiated 10/100Mbps, Half or Full Duplex.
- Flexible Quad or Hex RTD Inputs Accepts four or six channels of input for Platinum (Pt), Copper (Cu), and Nickel (Ni) RTD types, or simple resistance. RTD's are connected in 2 or 3 wire fashion. Linearization, excitation, lead break detection, and lead-wire compensation (3-wire) are included.
- Ratiometric Differential RTD Sampling The RTD is sampled differentially using ratiometric conversion and this increases accuracy.
- Automatic Self-Calibration Built-in self-calibration helps correct for temperature drift of the input circuit every 60 seconds.
- **Upscale Or Downscale Break Detection** Inputs may be configured to go upscale or downscale upon lead breakage.
- **Precise High-Resolution A/D Conversion** Modules use high-resolution, low noise, sigma-delta analog-to-digital conversion for high accuracy and reliability.
- Plug-In Terminal Blocks & DIN-Rail Mount Make mounting, removal, and replacement easy.
- **Nonvolatile Reprogrammable Memory** Allows the functionality of this device to be reliably reprogrammed thousands of times.
- Operation/Diagnostic LED Indicators Aide Troubleshooting Yellow ACT LED indicates port activity. Green LNK LED indicates link (autonegotiation complete and connection established). Green RUN LED indicates power/wink ID mode. Yellow ST LED indicates module status.
- Internal Watchdog A hardware watchdog timer is built into the microcontroller that causes it to initiate a self reset if the controller ever "locks up" or fails to return from an operation in a timely manner.
- **Wide-Range DC-Power** Wide range diode-coupled for use with redundant supplies, and/or battery back-up.
- Hardened For Harsh Environments For protection from RFI, EMI, ESD, EFT, & surges. Has low radiated emissions per CE requirements.
- Wide Ambient Operation Reliable over a wide temperature range.

19

These input modules will process up to four or six RTD input signals. according to model number, and provide an isolated 10/100 Ethernet interface for configuration, monitoring, and control of the input module. One A/D is provided for every pair of input channels and each input drives a separate A/D channel. An integrated multiplexer and analog switch are used to connect each of two A/D input channels to the A/D converter. The A/D converter then applies appropriate gain to the signals, performs analog-todigital conversion, and digitally filters the signals. The digitized A/D signal is then transmitted serially to a microcontroller. The microcontroller completes the transfer function according to the input type/range per its embedded program. Configuration and calibration parameters are stored in non-volatile memory integrated within the microcontroller. A dedicated Ethernet controller handles Ethernet communication. The I/O terminals and the Ethernet port terminals also include transient suppression. A wide input switching regulator (isolated flyback) provides isolated power to the I/O circuits and the Ethernet controller. Refer to the simplified schematic shown below to help gain a better understanding of the circuit.

## **HOW IT WORKS**



Note that input types may vary between channel pairs, but pair members share the same input range configuration—channel 0 and 1 may be configured differently from channel 2 and 3, and channel 4 and 5. All inputs share the same break detect direction, upscale or downscale. Inputs are not isolated channel-to-channel.

## ABOUT MODBUS TCP/IP


You can find more information on Modbus TCP/IP by visiting our web site and down-loading whitepaper 8500-765, Introduction To Modbus TCP/IP. TCP/IP is the foundation for the World Wide Web and refers to Transmission Control Protocol and Internet Protocol. TCP/IP allows blocks of binary data to be exchanged between computers. The primary function of TCP is to ensure that all packets of data are received correctly. IP makes sure that messages are correctly addressed and routed. Note that the TCP/IP combination does not define what the data means or how the data is to be interpreted, it is merely a *transport protocol*.

Modbus is an *application protocol*. It defines rules for organizing and interpreting data and is essentially a messaging structure that is independent of the underlying physical layer. It is freely available and accessible to anyone, easy to understand, and widely supported by many manufacturers.

Modbus TCP/IP uses TCP/IP and Ethernet to carry the data of the Modbus message structure between devices. That is, Modbus TCP/IP combines a physical network (Ethernet), with a networking standard (TCP/IP), and a standard method of representing data (Modbus). A Modbus TCP/IP message is simply a Modbus communication encapsulated in an Ethernet TCP/IP wrapper.

In practice, Modbus TCP embeds a Modbus data frame into a TCP frame, without the Modbus checksum, as shown in the following diagram. The Modbus checksum is not used, as the standard Ethernet TCP/IP link layer checksum methods are instead used to guaranty data integrity.

#### TCP FRAME



Note that the Modbus address field is referred to as the *Unit Identifier* in Modbus TCP. In a typical slave application, the Unit ID is ignored and just echoed back in the response.

The operation of the 966EN industrial Ethernet modules is similar to Acromag's 932/934MB Modbus modules. The operation over Ethernet is essentially transparent to the Modbus register/command structure. If you are already familiar with Modbus or with Acromag Series 900MB modules, then you are already familiar with the operation of the 966EN modules.

## **IP Addressing**

A host is any device on any network. On TCP/IP networks, each host has one or more unique IP addresses. This module connected to an Ethernet network is a host.

An IP Address is a unique identification number for any host (this module) on any TCP/IP network (including the internet). The IP address is made up of four octets (8 bits), each octet having a value between 0-255 (00H-FFH). The IP address is comprised of two parts: the network address (first part) and the host address (last part). The number of octets of the four total that belong to the network address depend on the Class definition (see below).

21

A *Static IP Address* is as the name implies—static. That is, it is a unique IP Address that is assigned by a service provider and never changes.

**IP Addressing** 

A *Dynamic IP Address* is an address that is temporarily assigned to a user by a service provider each time a user connects.

A *Subnet* is a contiguous string of IP addresses. The first IP address in a subnet is used to identify the subnet and usually addresses the server for the subnet. The last IP address in a subnet is always used as a broadcast address and anything sent to the last IP address of a subnet is sent to every host on that subnet.

Subnets are further broken down into three size classes based on the 4 octets that make up the IP address. A Class A subnet is any subnet that shares the first octet of the IP address. The remaining 3 octets of a Class A subnet will define up to 16,777,214 possible IP addresses ( $2^{24}-2$ ). A Class B subnet shares the first two octets of an IP address (providing  $2^{16}-2$ , or 65534 possible IP addresses). Class C subnets share the first 3 octets of an IP address, giving 254 possible IP addresses. Recall that the first and last IP addresses are always used as a network number and broadcast address respectively, and this is why we subtract 2 from the total possible unique addresses that are defined via the remaining octet(s).

For our example, the default IP address of this module is 128.1.1.100. If we assume that this is a Class C network address (based on the default Class C subnet mask of 255.255.255.0), then the first three numbers represent this Class C network at address 128.1.1.0, the last number identifies a unique host/node on this network (node 100) at address 128.1.1.100.

A *Subnet Mask* is used to determine which subnet an IP address belongs to. The use of a subnet mask allows the network administrator to further divide the host part of this address into two or more subnets. The subnet mask flags the network address portion of the IP address, plus the bits of the host part that are used for identifying the sub-network. By convention, the bits of the mask that correspond to the sub-network address are all set to 1's (it would also work if the bits were set exactly as in the network address). It's called a mask because it can be used to identify the unique subnet to which an IP address belongs to by performing a bitwise AND operation between the mask itself, and the IP address, with the result being the sub-network address, and the remaining bits the host or node address.

Subnetwork address 128.1.1.0 has 254 possible unique node addresses. We are using node 100 of 254 possible for our module.

Note that the first node address (0) and node 10 are typically reserved for servers and should not be used. The last node (255) is a broadcast address. Node 100 is the default address of this module. Use of these node addresses for any other purpose may yield poor performance.

## Dynamic Host Configuration Protocol (DHCP)

DHCP refers to Dynamic Host Configuration Protocol and is a method used to dynamically assign temporary numeric IP addresses as required. A DHCP server maintains a pool of shared IP addresses which are recycled. When a DHCP device wants to use a TCP/IP application, it must request an IP address from the DHCP server. The DHCP server will check the shared supply, and if all addresses are in use, the server will send a busy signal to the client which tells it to try again later. Static addresses will ensure a connection every time, but dynamic addresses do not.

## Domain Name System (DNS)

DNS refers to the Domain Name System or Domain Name Server and refers to the system used to associate an alphanumeric character string with a numeric IP address. The DNS is actually a distributed database of domain names and corresponding IP addresses. The DNS allows us to use Acromag.com as an IP address rather than a complicated string of numbers. Note that name servers contain information on some segment of the domain name space and make this information available to clients called *resolvers*.

## MODBUS REGISTERS

Modbus registers are organized into reference types identified by the leading number of the reference address:

The "x" following the leading character represents a four-digit address location in user data memory.

Reference	Description	
0xxxx	Read/Write Discrete Outputs or Coils. A 0x reference	
	address is used to drive output data to a digital output channel.	
1xxxx	Read Discrete Inputs. The ON/OFF status of a 1x reference address is controlled by the corresponding digital input channel.	
Зхххх	Read Input Registers. A 3x reference register contains a 16-bit number received from an external source—e.g. an analog signal.	
4xxxx	Read/Write Output or Holding Registers. A 4x register is used to store 16-bits of numerical data (binary or decimal), or to send the data from the CPU to an output channel.	

The leading character is generally implied by the function code and omitted from the address specifier for a given function. The leading character also identifies the I/O data type.

Note: The ON/OFF state of discrete inputs and outputs is represented by a 1 or 0 value assigned to an individual bit in a 16-bit data word. This is sixteen 0x or 1x references per data word. With respect to mapping, the LSB of the word maps to the lowest numbered channel of a group and channel numbers increase sequentially as you move towards the MSB. Unused bit positions are set to zero.

All I/O values are accessed via the 16-bit Input or Holding Registers given in the Register Map. Input registers contain read-only information. For example, the current input value read from a channel, or the states of a group of digital inputs. Holding registers contain read/write information that may be configuration data or output data. For example, the high limit value of an alarm operating at an input, or an output value for an output channel.

## **Register Functions**

Each module has a default factory configuration as noted in the SPECIFICATIONS section. Your application will likely differ from the default configuration and the module will need to be reconfigured. You may reconfigure this module by issuing the appropriate Modbus functions to Register Map registers, as required by your application. You may also use a standard web browser to access the built-in web pages of the module to perform basic operations.

23

Below is a subset of standard Modbus functions that are supported by this module along with the reference register addresses that the function operates on. Use these functions to access these registers as outlined in the Register Map for sending and retrieving data.

**Register Functions** 

The following Modbus functions operate on register map registers to monitor, configure, and control module I/O:

CODE	FUNCTION	REFERENCE
01 (01H)	Read Coil (Output) Status	0xxxx
02 (02H)	Read Input Status	1xxxx
03 (03H)	Read Holding Registers	4xxxx
04 (04H)	Read Input Registers	3xxxx
05 (05H)	Force Single Coil (Output)	0xxxx
06 (06H)	Preset Single Register	4xxxx
15 (0FH)	Force Multiple Coils (Outputs)	0xxxx
16 (10H)	Preset Multiple Registers	4xxxx
17 (11H)	Report Slave ID (See Below)	Hidden

If an unsupported function code is sent to a module, exception code 01 (Illegal Function) will be returned in the response. If a holding register is written with an invalid value, exception code 03 (Illegal Data Value) will be returned in the response message. You may refer to the Modbus specification for a complete list of possible error codes.

966EN-4006 Report Slave ID Example Response<sup>1</sup>

FIELD	DESCRIPTION
Unit ID	Echo Unit ID Sent In Query
Function Code	11
Byte Count	42
Slave ID (Model No.)1	06H=966EN-4004 (4 RTD Inputs)
	07H=966EN-4006 (6 RTD Inputs)
Run Indicator Status	FFH (ON)
Firmware Number	41 43 52 4F 4D 41 47 2C 39 33 30 30 2D
String (Additional	<b>31 32 35</b> 2C 39 <b>36 36</b> 45 4E 2D <b>34 30 30 36</b> 2C
Data Field)1	30 31 32 33 34 35 41 2C 30 31 32 33 34 35
	("ACROMAG,9300- <b>125</b> ,9 <b>66</b> EN- <b>4006</b> ,serial
	number&rev,six-byteMACID")

<sup>1</sup>Note: Model 966EN-4004 slave ID is "06" and the firmware is 9300-124. Model 966EN-4006 slave ID is "07" and the firmware is 9300-125.

For detailed information on Modbus, feel free to download our technical reference 8500-648, "Introduction To Modbus", and whitepaper 8500-765, "Introduction To Modbus TCP/IP" at <a href="www.acromag.com">www.acromag.com</a>.

For your convenience, 9xxEN Ethernet modules mirror the contents and operation of registers 0xxxx, 1xxxx, & 3xxxx (as applicable) into holding register space for systems and controllers that cannot directly access registers 0xxxx, 1xxxx, & 3xxxx.

All Modbus registers of this model can now be written to, or read from, using either the standard methods described in the Modbus specification, or through mapping (mirroring) to the Holding Registers. The registers are mapped as follows and specifics follow the mapping:

**Register Mirroring** 

## **Register Mirroring**

Oxxxx Coil Registers are mapped to 42xxx Holding Registers
1xxxx Input Status Registers are mapped to 41xxx Holding Registers
3xxxx Input Registers are mapped to 43xxx Holding Registers
For 3xxxx Input Registers, the format of the registers are identical and you
only need to offset your address by 43000. For example: if you want to read
Input Register 1 through the Holding Registers, you would use the "Read
Holding Registers" function with an address of 43001.

For the 1xxxx Input Status Registers (where supported), the return data is reformatted to match the Holding Register format. For example: if you request the Input Status for 12 digital inputs, instead of getting 2 bytes returned with the first 12 bits representing the 12 digital inputs, you will get 12 separate words, each set to either 0000H (OFF), or FFFFH (ON).

For the 0xxxx Coil Registers (where supported), reads are handled in the same way as the 1xxxx Input Status Registers. You can also write to the coil registers by using the "Preset Single Register" function with an address offset of 42000. Setting the data to 0000H will turn the coil OFF, while setting the data to FF00H will turn the coil ON. Writing to multiple coils is not supported via register mirroring, you must use the "Write Multiple Coils" function for that.

Note that with respect to Acromag 9xxMB Modbus RTU modules, only 3xxxx Input Registers are mirrored into 4xxxx space, not Coil or Input Status registers as noted here for 9xxEN models.

**Data Types** 

I/O values for Series 900EN modules are represented by the following simple data types for temperature, percentage, and discrete on/off.

Summary Of Data Types Used By 900MB/900EN Modules

Data Types	Description	
Normalized Data Count	A 16-bit signed integer value where 0-7FFFH is a positive number and 8000H-FFFFH is a negative number. For example when using the 0-500 $\Omega$ device, the input of $0\Omega$ is represented by 0, 250 $\Omega$ by a count of 16000 and 500 $\Omega$ is represented by 32000.	
Temperature (This Model)	Internally, RTD values are represented via 16-bit signed integers with a resolution of 0.1°C/lsb. As such, a count of 0-7FFFH is a positive number, while 8000-FFFFH is a negative number. However, the upscale/downscale break counts are trimmed to a reasonable range value according to the RTD type. The downscale (break) detent is 63105 (Pt385), 63141 (Pt391), 63715 (Ni), and 63281 (Cu). The upscale break detent is 12618 (Pt385), 12421 (Pt391), 3455 (Ni), and 32767 (Cu).	
Discrete	A discrete value is generally indicated by a single bit of a 16-bit word. The bit number/position typically corresponds to the discrete channel number. Unless otherwise defined for outputs, a 1 bit means the corresponding output is closed or ON, a 0 bit means the output is open or OFF. For inputs, a value of 1 means the input is ON (Active low near 0V), while a value of 0 specifies the input is OFF or in its high state (usually >> 0V).	

25

The following table outlines the register map for the Model 966EN-4006 and 966EN-4004 network input modules. The Modbus functions operate on these registers using the data types noted above (except for the Reset Slave and Report Slave ID functions). Unless otherwise noted, Holding Register values are maintained in flash memory and are non-volatile.

Ref	Addr.	Description	Data Type/Format		
	Input Registers (3x References, Read-Only)				
<b>3</b> 0001	0000	Module Status	Bit 15: 0 (Not Used) Bit 14: Wink Mode Flag		
		Status		ode (Blinks Run LED for ID)	
			0 = Normal (		
			(See Wink M	nodule Register)	
			Bit 13: Defau	ult Mode Flag	
			1 = Default N 0 = Not Defa	Mode Indicator	
			Bits 12-0: 0		
<b>3</b> 0002	0001	CH 0,1	Bits 15-4	0 (Not Used)	
		(Port 0)	Bit 3,2,1,0:	Input Range	
		Input Range	0000	$0=3W \text{ Pt } 100\Omega \ (\alpha=1.3850)$	
		& Wiring (2 or 3 Wire)	0001	1=3W Pt 100Ω (α=1.3911)	
		(2013 Wile)	0010	2=3W Ni 120Ω	
			0011	3=3W Cu 10Ω	
			0100	4=3W Resistance 0-500 $\Omega$	
			0101	5=2W Pt 100Ω ( $\alpha$ =1.3850)	
			0110	6=2W Pt 100Ω (α=1.3911)	
			0111	7=2W Ni 120Ω	
			1000	8=2W Cu 10Ω	
			1001	9=2W Resistance 0-500Ω	
<b>3</b> 0003	0002	CH2,3	1010-1111	10-15=Reserved ame as for CH0,1(Port 0).	
<b>3</b> 0003	0002	(Port 1)	Format is sa	irrie as for Cho, r(Port o).	
		Input Range			
<b>3</b> 0004	0003	CH4,5		me as for CH0,1(Port 0).	
		(Port 2)		ly present on 6 channel	
		Input Range 966EN-4006	model 966EN-4006.		
<b>3</b> 0005	0004	Break	Bits 15-1:	0 (Not Used)	
		Detection	Bit 0:	Break Detect Direction:	
			0	Upscale Break	
<b>3</b> 0006	0005	CH00 Status	Bits 15-2:	Downscale Break 0 (Not Used)	
30000	0003	Ci ioo Status	Bits 1,0:	Input Signal Status	
			00	In Range	
			01	Over-Range	
			10	Under-Range	
			11	Not Used	

## **Register Map**

## Model 966EN-4004 Model 966EN-4006

Note (Lead Break): RTD values are represented via 16bit signed integers with a resolution of 0.1 ℃/lsb and a possible range of −3276.8°C to +3276.7°C. As such, a count of 0-7FFFH is a positive number, while 8000-FFFH is a negative number. However, the upscale/downscale break counts are trimmed to a reasonable range value according to the RTD type. The downscale (break) detent is 63105 (Pt385), 63141 (Pt391), 63715 (Ni), and 63281 (Cu). The upscale break detent is 12618 (Pt385). 12421 (Pt391), 3455 (Ni), and 32767 (Cu).

Model 966EN-4004 Model 966EN-4006

Ref	Addr.	Description	Data Type/Format	
Input R	egisters	(3x References,	, Read-Only)	
<b>3</b> 0007	0006	CH01 Status	Bits 15-2:	0 (Not Used)
			Bits 1,0:	Input Signal Status
			00	In Range
			01	Over-Range
			10	Under-Range
		01100 01 1	11	Not Used
<b>3</b> 0008	0007	CH02 Status	Bits 15-2:	0 (Not Used)
			Bits 1,0:	Input Signal Status
			00	In Range
			01	Over-Range
			10	Under-Range
			11	Not Used
<b>3</b> 0009	8000	CH03 Status	Bits 15-2:	0 (Not Used)
			Bits 1,0:	Input Signal Status
			00	In Range
			01	Over-Range
			10	Under-Range
			11	Not Used
<b>3</b> 0010	0009	CH04 Status	Bits 15-2:	0 (Not Used)
		966EN-4006	Bits 1,0:	Input Signal Status
			00	In Range
			01	Over-Range
			10	Under-Range
			11	Not Used
<b>3</b> 0011	000A	CH05 Status	Bits 15-2:	0 (Not Used)
		966EN-4006	Bits 1,0:	Input Signal Status
			00	In Range
			01	Over-Range
			10	Under-Range
			11	Not Used
<b>3</b> 0012	000B	CH00 Value		emperature (°C)
<b>3</b> 0013	000C	CH01 Value		emperature (°C)
<b>3</b> 0014	000D	CH02 Value	<u> </u>	emperature (°C)
<b>3</b> 0015	000E	CH03 Value		emperature (°C)
<b>3</b> 0016	000F	CH04 Value		emperature (°C)
		966EN-4006		, ,
<b>3</b> 0017	0010	CH05 Value	Count or Te	emperature (°C)
		966EN-4006		
<b>3</b> 0018	0011	CH00 Count	Raw A/D Co	ount Value
<b>3</b> 0019	0012	CH01 Count	Raw A/D Co	
<b>3</b> 0020	0013	CH02 Count	Raw A/D Co	
<b>3</b> 0021	0014	CH03 Count	Raw A/D Co	
<b>3</b> 0022	0015	CH04 Count	Raw A/D Co	ount Value
	00:-	966EN-4006		
<b>3</b> 0023	0016	CH05 Count	Raw A/D Co	ount Value
		966EN-4006		

Ref	Addr.	Description	Data Type/Format	
Holding	g Registe	ers (4x Referen	ces, Read/Wr	ite)
<b>4</b> 0001	0000	CH 0,1	Bits 15-4	0 (Not Used)
		(Port 0)	Bit 3,2,1,0:	Input Range
		Input Range	0000	0=3W Pt 100Ω (α=1.3850)
		& Wiring	0001	1=3W Pt 100Ω (α=1.3911)
		(2 or 3 Wire)	0010	2=3W Ni 120Ω
			0011	3=3W Cu 10Ω
			0100	4=3W Resistance 0-500Ω
			0101	5=2W Pt 100Ω (α=1.3850)
			0110	6=2W Pt 100Ω (α=1.3911)
			0111	7=2W Ni 120Ω
			1000	8=2W Cu 10Ω
			1001	9=2W Resistance 0-500Ω
			1010-1111	10-15=Reserved
<b>4</b> 0002	0001	CH2,3	Format is sa	me as for CH0,1(Port 0).
		(Port 1)		
		Input Range		
<b>4</b> 0003	0002	CH4,5 (Port 2)	Format is sa	me as for CH0,1(Port 0).
		Input Range	This port only	y present on 6 channel
		966EN-4006	model 966El	
<b>4</b> 0004	0003	Break	Bits 15-1:	0 (Not Used)
		Detection	Bit 0:	Break Detect Direction:
			0	Upscale Break
			1	Downscale Break
<b>4</b> 0005	0004	Reserved	Do Not Use	
<b>4</b> 0006	0005	Reserved	Do Not Use	
<b>4</b> 0007	0006	Reserved	Do Not Use	
<b>4</b> 0008	0007	Port 0		
		Scaling Low		
<b>4</b> 0009	8000	Reserved	Do Not Use	
<b>4</b> 0010	0009	Port 0		
		Scaling High		
<b>4</b> 0011	000A	Reserved	Do Not Use	
<b>4</b> 0012	000B	Port 1		
		Scaling Low		
<b>4</b> 0013	000C	Reserved	Do Not Use	
<b>4</b> 0014	000D	Port 1		
		Scaling High		
<b>4</b> 0015	000E	Reserved	Do Not Use	
<b>4</b> 0016	000F	Port 2		
	0015	Scaling Low	5	
<b>4</b> 0017	0010	Reserved	Do Not Use	
<b>4</b> 0018	0011	Port 2		
		Scaling High		
<b>4</b> 0019	0012	Reserved	Do Not Use	
<b>4</b> 0020	0013	Reserved	Do Not Use	

## Model 966EN-4004 Model 966EN-4006

**Note:** Changes to Holding Registers take effect immediately.

Model 966EN-4004 Model 966EN-4006

Ref	Addr.	Description	Data Type/Format
Holding	g Registe	ers (4x Referenc	es, Read/Write)
<b>4</b> 0021	0014	Calibration	Writing 24106 (5E2AH) here
		Access	immediately removes write protection
			from the calibration registers that follow.
			All other values apply write protection to
		And	the calibration registers, except as
			noted below (21845, 44718, & 43981).
		Wink Mode	
		Toggle	Writing 21845 (5555H) to this register
			will cause the module to "Wink" its Run
			LED. Writing this value a second time
		And	will stop "Wink" (Toggles Wink
		Dootoro	ON/OFF).
		Restore Factory	Writing 44718 (AEAEH) will cause the
		Calibration	module to restore its factory calibration.
		Calibration	This can only be done after "Save
		And	Factory Calibration" has been done at
		7	the factory.
		FACTORY	,
		USE ONLY-	Writing 43981 (ABCDH) is reserved for
			factory use. This should not be
			performed by anyone else or
			operation will be degraded.
			This register always reads back 0.
			After a reset, this register is set back to
			0 (write protection enabled and no
			wink).
			This was into a large majortain and in fleah
40000	0045	0110 0-111	This register is not maintained in flash.
<b>4</b> 0022	0015	CH0 Cal Hi 3W Range 0	Raw A/D Count Value .   3W Pt 100Ω (α=1.3850)
<b>4</b> 0023	0016	CH0 Cal Lo	Raw A/D Count Value .
40023	0010	3W Range 0	$3W Pt 100\Omega (\alpha=1.3850)$
<b>4</b> 0024	0017	CH0 Cal Hi	Raw A/D Count Value .
10021	0011	3W Range 1	$3W Pt 100\Omega (\alpha=1.3911)$
<b>4</b> 0025	0018	CH0 Cal Lo	Raw A/D Count Value .
		3W Range 1	3W Pt 100Ω (α=1.3911)
<b>4</b> 0026	0019	CH0 Cal Hi	Raw A/D Count Value .
		3W Range 2	3W Ni 120Ω (α=1.6720)
<b>4</b> 0027	001A	CH0 Cal Lo	Raw A/D Count Value .
		3W Range 2	3W Ni 120Ω (α=1.6720)
<b>4</b> 0028	001B	CH0 Cal Hi	Raw A/D Count Value .
40.000	2012	3W Range 3	3W Cu 10Ω (α=1.4272)
<b>4</b> 0029	001C	CH0 Cal Lo	Raw A/D Count Value .
40000	0040	3W Range 3	3W Cu 10Ω (α=1.4272)
<b>4</b> 0030	001D	CH0 Cal Hi	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω

Ref	Addr.	Description	Data Type/Format
Holding	Registe	ers (4x Referenc	es, Read/Write)
<b>4</b> 0031	001E	CH0 Cal Lo	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω
<b>4</b> 0032	001F	CH0 Cal Hi	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω (α=1.3850)
<b>4</b> 0033	0020	CH0 Cal Lo	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω (α=1.3850)
<b>4</b> 0034	0021	CH0 Cal Hi	Raw A/D Count Value .
		2W Range 6	$2W Pt 100\Omega (\alpha=1.3911)$
<b>4</b> 0035	0022	CH0 Cal Lo	Raw A/D Count Value .
		2W Range 6	$2W Pt 100\Omega (\alpha=1.3911)$
<b>4</b> 0036	0023	CH0 Cal Hi	Raw A/D Count Value .
		2W Range 7	2W Ni 120Ω (α=1.6720)
<b>4</b> 0037	0024	CH0 Cal Lo	Raw A/D Count Value .
		2W Range 7	2W Ni 120Ω (α=1.6720)
<b>4</b> 0038	0025	CH0 Cal Hi	Raw A/D Count Value .
		2W Range 8	2W Cu 10Ω (α=1.4272)
<b>4</b> 0039	0026	CH0 Cal Lo	Raw A/D Count Value .
		2W Range 8	2W Cu 10Ω (α=1.4272)
<b>4</b> 0040	0027	CH0 Cal Hi	Raw A/D Count Value .
40044	0000	2W Range 9	2W Resistance 0-500Ω
<b>4</b> 0041	0028	CH0 Cal Lo	Raw A/D Count Value .
	2222	2W Range 9	2W Resistance 0-500Ω
<b>4</b> 0042	0029	CH1 Cal Hi	Raw A/D Count Value .
40040	0004	3W Range 0	$3W Pt 100\Omega (\alpha = 1.3850)$
<b>4</b> 0043	002A	CH1 Cal Lo	Raw A/D Count Value .
40044	0000	3W Range 0	$3W Pt \ 100\Omega \ (\alpha = 1.3850)$
<b>4</b> 0044	002B	CH1 Cal Hi	Raw A/D Count Value .
40045	0000	3W Range 1 CH1 Cal Lo	3W Pt 100Ω (α=1.3911)  Raw A/D Count Value .
<b>4</b> 0045	002C		
<b>4</b> 0046	002D	3W Range 1 CH1 Cal Hi	3W Pt 100Ω (α=1.3911)  Raw A/D Count Value .
40046	0020	3W Range 2	3W Ni 120Ω (α=1.6720)
<b>4</b> 0047	002E	CH1 Cal Lo	Raw A/D Count Value .
40047	002L	3W Range 2	$3W Ni 120\Omega (\alpha=1.6720)$
<b>4</b> 0048	002F	CH1 Cal Hi	Raw A/D Count Value .
<b>4</b> 0040	0021	3W Range 3	$3W Cu 10\Omega (\alpha=1.4272)$
<b>4</b> 0049	0030	CH1 Cal Lo	Raw A/D Count Value .
40040	0000	3W Range 3	$3W Cu 10\Omega (\alpha=1.4272)$
<b>4</b> 0050	0031	CH1 Cal Hi	Raw A/D Count Value .
		3W Range 4	$3W$ Resistance 0-500 $\Omega$
<b>4</b> 0051	0032	CH1 Cal Lo	Raw A/D Count Value .
		3W Range 4	$3W$ Resistance 0-500 $\Omega$
<b>4</b> 0052	0033	CH1 Cal Hi	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω (α=1.3850)
<b>4</b> 0053	0034	CH1 Cal Lo	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω (α=1.3850)
<b>4</b> 0054	0035	CH1 Cal Hi	Raw A/D Count Value .
		2W Range 6	2W Pt 100Ω (α=1.3911)
<b>4</b> 0055	0036	CH1 Cal Lo	Raw A/D Count Value .
		2W Range 6	2W Pt 100Ω (α=1.3911)

## Model 966EN-4004 Model 966EN-4006



## Model 966EN-4004 Model 966EN-4006

Ref	Addr.	Description	Data Type/Format
		· · · · · · · · · · · · · · · · · · ·	ces, Read/Write)
<b>4</b> 0056	0037	CH1 Cal Hi	Raw A/D Count Value .
40000	0037	2W Range 7	$2W \text{ Ni } 120\Omega  (\alpha=1.6720)$
<b>4</b> 0057	0038	CH1 Cal Lo	Raw A/D Count Value .
40007	0000	2W Range 7	$2W Ni 120\Omega (\alpha=1.6720)$
<b>4</b> 0058	0039	CH1 Cal Hi	Raw A/D Count Value .
40000	0000	2W Range 8	$2W Cu 10\Omega (\alpha=1.4272)$
<b>4</b> 0059	003A	CH1 Cal Lo	Raw A/D Count Value .
40000	000/1	2W Range 8	$2W Cu 10\Omega (\alpha=1.4272)$
<b>4</b> 0060	003B	CH1 Cal Hi	Raw A/D Count Value .
1000		2W Range 9	2W Resistance 0-500Ω
<b>4</b> 0061	003C	CH1 Cal Lo	Raw A/D Count Value .
		2W Range 9	2W Resistance 0-500Ω
<b>4</b> 0062	003D	CH2 Cal Hi	Raw A/D Count Value .
.000_	0002	3W Range 0	$3W Pt 100\Omega (\alpha=1.3850)$
<b>4</b> 0063	003E	CH2 Cal Lo	Raw A/D Count Value .
10000	0002	3W Range 0	$3W Pt 100\Omega (\alpha=1.3850)$
<b>4</b> 0064	003F	CH2 Cal Hi	Raw A/D Count Value .
		3W Range 1	$3W Pt 100\Omega (\alpha=1.3911)$
<b>4</b> 0065	0040	CH2 Cal Lo	Raw A/D Count Value .
		3W Range 1	$3W Pt 100\Omega (\alpha=1.3911)$
<b>4</b> 0066	0041	CH2 Cal Hi	Raw A/D Count Value .
		3W Range 2	3W Ni 120Ω (α=1.6720)
<b>4</b> 0067	0042	CH2 Cal Lo	Raw A/D Count Value .
		3W Range 2	3W Ni 120Ω (α=1.6720)
<b>4</b> 0068	0043	CH2 Cal Hi	Raw A/D Count Value .
		3W Range 3	3W Cu 10Ω (α=1.4272)
<b>4</b> 0069	0044	CH2 Cal Lo	Raw A/D Count Value .
		3W Range 3	3W Cu 10Ω (α=1.4272)
<b>4</b> 0070	0045	CH2 Cal Hi	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω
<b>4</b> 0071	0046	CH2 Cal Lo	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω
<b>4</b> 0072	0047	CH2 Cal Hi	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω (α=1.3850)
<b>4</b> 0073	0048	CH2 Cal Lo	Raw A/D Count Value .
100=	00:0	2W Range 5	2W Pt 100Ω (α=1.3850)
<b>4</b> 0074	0049	CH2 Cal Hi	Raw A/D Count Value .
40075	0044	2W Range 6	2W Pt 100Ω (α=1.3911)
<b>4</b> 0075	004A	CH2 Cal Lo	Raw A/D Count Value .
40070	00.45	2W Range 6	$2W Pt 100\Omega (\alpha=1.3911)$
<b>4</b> 0076	004B	CH2 Cal Hi	Raw A/D Count Value .
40077	0040	2W Range 7	2W Ni 120Ω (α=1.6720)
<b>4</b> 0077	004C	CH2 Cal Lo	Raw A/D Count Value .
40070	0040	2W Range 7	2W Ni 120Ω (α=1.6720)
<b>4</b> 0078	004D	CH2 Cal Hi	Raw A/D Count Value .
40070	0045	2W Range 8 CH2 Cal Lo	2W Cu 10Ω (α=1.4272)
<b>4</b> 0079	004E	2W Range 8	Raw A/D Count Value .
40080	004F	CH2 Cal Hi	2W Cu 10Ω (α=1.4272)
40000	004F	2W Range 9	Raw A/D Count Value .
		ZW Nange 9	2W Resistance 0-500Ω

Ref	Addr.	Description	Data Type/Format
	l e		ces, Read/Write)
<b>4</b> 0081	0050	CH2 Cal Lo	Raw A/D Count Value .
40001	0000	2W Range 9	2W Resistance 0-500Ω
<b>4</b> 0082	0051	CH3 Cal Hi	Raw A/D Count Value .
40002	0031	3W Range 0	$3W Pt 100\Omega (\alpha=1.3850)$
<b>4</b> 0083	0052	CH3 Cal Lo	Raw A/D Count Value .
40000	0002	3W Range 0	$3W Pt 100\Omega (\alpha=1.3850)$
<b>4</b> 0084	0053	CH3 Cal Hi	Raw A/D Count Value .
1000		3W Range 1	3W Pt 100Ω (α=1.3911)
<b>4</b> 0085	0054	CH3 Cal Lo	Raw A/D Count Value .
		3W Range 1	3W Pt 100Ω (α=1.3911)
<b>4</b> 0086	0055	CH3 Cal Hi	Raw A/D Count Value .
		3W Range 2	3W Ni 120Ω (α=1.6720)
<b>4</b> 0087	0056	CH3 Cal Lo	Raw A/D Count Value .
		3W Range 2	3W Ni 120Ω (α=1.6720)
<b>4</b> 0088	0057	CH3 Cal Hi	Raw A/D Count Value .
		3W Range 3	3W Cu 10Ω (α=1.4272)
<b>4</b> 0089	0058	CH3 Cal Lo	Raw A/D Count Value .
		3W Range 3	3W Cu 10Ω (α=1.4272)
<b>4</b> 0090	0059	CH3 Cal Hi	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω
<b>4</b> 0091	005A	CH3 Cal Lo	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω
<b>4</b> 0092	005B	CH3 Cal Hi	Raw A/D Count Value .
	22.50	2W Range 5	2W Pt 100Ω (α=1.3850)
<b>4</b> 0093	005C	CH3 Cal Lo	Raw A/D Count Value .
40004	0050	2W Range 5	$2W Pt 100\Omega (\alpha=1.3850)$
<b>4</b> 0094	005D	CH3 Cal Hi	Raw A/D Count Value .
40005	005E	2W Range 6 CH3 Cal Lo	2W Pt 100Ω (α=1.3911)  Raw A/D Count Value .
<b>4</b> 0095	005E	2W Range 6	2W Pt 100Ω (α=1.3911)
<b>4</b> 0096	005F	CH3 Cal Hi	Raw A/D Count Value .
40096	005F	2W Range 7	$2W Ni 120\Omega (\alpha=1.6720)$
<b>4</b> 0097	0060	CH3 Cal Lo	Raw A/D Count Value .
40031	0000	2W Range 7	$2W \text{ Ni } 120\Omega  (\alpha=1.6720)$
<b>4</b> 0098	0061	CH3 Cal Hi	Raw A/D Count Value .
.5050	3331	2W Range 8	$2W Cu 10\Omega (\alpha=1.4272)$
<b>4</b> 0099	0062	CH3 Cal Lo	Raw A/D Count Value .
		2W Range 8	2W Cu 10Ω (α=1.4272)
<b>4</b> 0100	0063	CH3 Cal Hi	Raw A/D Count Value .
		2W Range 9	2W Resistance 0-500Ω
<b>4</b> 0101	0064	CH3 Cal Lo	Raw A/D Count Value .
		2W Range 9	2W Resistance 0-500Ω
<b>4</b> 0102	0065	CH4 Cal Hi	Raw A/D Count Value .
		3W Range 0	3W Pt 100Ω (α=1.3850), 966EN-4006
<b>4</b> 0103	0066	CH4 Cal Lo	Raw A/D Count Value .
		3W Range 0	3W Pt 100Ω (α=1.3850), 966EN-4006
<b>4</b> 0104	0067	CH4 Cal Hi	Raw A/D Count Value .
		3W Range 1	<i>3W Pt 100</i> Ω (α=1.3911), <b>966EN-4006</b>
<b>4</b> 0105	0068	CH4 Cal Lo	Raw A/D Count Value .
		3W Range 1	3W Pt 100Ω (α=1.3911), 966EN-4006

## Model 966EN-4004 Model 966EN-4006

## Model 966EN-4004 Model 966EN-4006

Ref	Addr.	Description	Data Type/Format
Holding	. Reaiste		ces, Read/Write)
<b>4</b> 0106	0069	CH4 Cal Hi	Raw A/D Count Value .
40100	0000	3W Range 2	$3W \text{ Ni } 120\Omega \ (\alpha=1.6720), \ \textbf{966EN-4006}$
<b>4</b> 0107	006A	CH4 Cal Lo	Raw A/D Count Value .
40107	000/1	3W Range 2	$3W \text{ Ni } 120\Omega  (\alpha=1.6720),  \textbf{966EN-4006}$
<b>4</b> 0108	006B	CH4 Cal Hi	Raw A/D Count Value .
<b>4</b> 0100	0000	3W Range 3	$3W Cu 10\Omega (\alpha=1.4272), 966EN-4006$
<b>4</b> 0109	006C	CH4 Cal Lo	Raw A/D Count Value .
40100		3W Range 3	$3W Cu 10\Omega (\alpha=1.4272), 966EN-4006$
<b>4</b> 0110	006D	CH4 Cal Hi	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω, <b>966EN-4006</b>
<b>4</b> 0111	006E	CH4 Cal Lo	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω, <b>966EN-4006</b>
<b>4</b> 0112	006F	CH4 Cal Hi	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω ( $\alpha$ =1.3850), <b>966EN-4006</b>
<b>4</b> 0113	0070	CH4 Cal Lo	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω ( $\alpha$ =1.3850), <b>966EN-4006</b>
<b>4</b> 0114	0071	CH4 Cal Hi	Raw A/D Count Value .
		2W Range 6	2W Pt 100Ω ( $\alpha$ =1.3911), <b>966EN-4006</b>
<b>4</b> 0115	0072	CH4 Cal Lo	Raw A/D Count Value .
		2W Range 6	2W Pt 100Ω (α=1.3911), <b>966EN-4006</b>
<b>4</b> 0116	0073	CH4 Cal Hi	Raw A/D Count Value .
		2W Range 7	2W Ni 120Ω (α=1.6720), <b>966EN-4006</b>
<b>4</b> 0117	0074	CH4 Cal Lo	Raw A/D Count Value .
		2W Range 7	2W Ni 120Ω (α=1.6720), <b>966EN-4006</b>
<b>4</b> 0118	0075	CH4 Cal Hi	Raw A/D Count Value .
		2W Range 8	2W Cu 10Ω (α=1.4272), <b>966EN-4006</b>
<b>4</b> 0119	0076	CH4 Cal Lo	Raw A/D Count Value .
		2W Range 8	2W Cu 10Ω (α=1.4272), <b>966EN-4006</b>
<b>4</b> 0120	0077	CH4 Cal Hi	Raw A/D Count Value .
		2W Range 9	2W Resistance 0-500Ω, <b>966EN-4006</b>
<b>4</b> 0121	0078	CH4 Cal Lo	Raw A/D Count Value .
		2W Range 9	2W Resistance 0-500Ω, <b>966EN-4006</b>
<b>4</b> 0122	0079	CH5 Cal Hi	Raw A/D Count Value .
		3W Range 0	3W Pt 100Ω (α=1.3850), <b>966EN-4006</b>
<b>4</b> 0123	007A	CH5 Cal Lo	Raw A/D Count Value .
		3W Range 0	3W Pt 100Ω (α=1.3850), <b>966EN-4006</b>
<b>4</b> 0124	007B	CH5 Cal Hi	Raw A/D Count Value .
		3W Range 1	3W Pt 100Ω (α=1.3911), <b>966EN-4006</b>
<b>4</b> 0125	007C	CH5 Cal Lo	Raw A/D Count Value .
		3W Range 1	3W Pt 100Ω (α=1.3911), <b>966EN-4006</b>
<b>4</b> 0126	007D	CH5 Cal Hi	Raw A/D Count Value .
40407	0075	3W Range 2	3W Ni 120Ω (α=1.6720), <b>966EN-4006</b>
<b>4</b> 0127	007E	CH5 Cal Lo	Raw A/D Count Value .
40400	0075	3W Range 2	3W Ni 120Ω (α=1.6720), <b>966EN-4006</b>
<b>4</b> 0128	007F	CH5 Cal Hi	Raw A/D Count Value .
40400	0000	3W Range 3	3W Cu 10Ω (α=1.4272), <b>966EN-4006</b>
<b>4</b> 0129	0800	CH5 Cal Lo	Raw A/D Count Value .
		3W Range 3	3W Cu 10Ω (α=1.4272), <b>966EN-4006</b>

Ref	Addr.	Description	Data Type/Format
Holding	Registe	rs (4x Referenc	es, Read/Write)
<b>4</b> 0130	0081	CH5 Cal Hi	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω, <b>966EN-4006</b>
<b>4</b> 0131	0082	CH5 Cal Lo	Raw A/D Count Value .
		3W Range 4	3W Resistance 0-500Ω, <b>966EN-4006</b>
<b>4</b> 0132	0083	CH5 Cal Hi	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω ( $\alpha$ =1.3850), <b>966EN-4006</b>
<b>4</b> 0133	0084	CH5 Cal Lo	Raw A/D Count Value .
		2W Range 5	2W Pt 100Ω (α=1.3850), 966EN-4006
<b>4</b> 0134	0085	CH5 Cal Hi	Raw A/D Count Value .
		2W Range 6	2W Pt 100Ω ( $\alpha$ =1.3911), <b>966EN-4006</b>
<b>4</b> 0135	0086	CH5 Cal Lo	Raw A/D Count Value .
		2W Range 6	2W Pt 100Ω (α=1.3911), 966EN-4006
<b>4</b> 0136	0087	CH5 Cal Hi	Raw A/D Count Value .
		2W Range 7	2W Ni 120Ω (α=1.6720), <b>966EN-4006</b>
<b>4</b> 0137	0088	CH5 Cal Lo	Raw A/D Count Value .
		2W Range 7	2W Ni 120Ω (α=1.6720), <b>966EN-4006</b>
<b>4</b> 0138	0089	CH5 Cal Hi	Raw A/D Count Value .
	0004	2W Range 8	2W Cu $10Ω$ ( $α=1.4272$ ), <b>966EN-4006</b>
<b>4</b> 0139	A800	CH5 Cal Lo	Raw A/D Count Value .
40440	0000	2W Range 8	2W Cu 10Ω (α=1.4272), <b>966EN-4006</b>
<b>4</b> 0140	008B	CH5 Cal Hi	Raw A/D Count Value .
404.44	0000	2W Range 9 CH5 Cal Lo	2W Resistance 0-500Ω, <b>966EN-4006</b>
<b>4</b> 0141	008C	2W Range 9	Raw A/D Count Value .
40440	0000		2W Resistance 0-500Ω, <b>966EN-4006</b>
<b>4</b> 0142	008D	Ideal Pt385	Ideal A/D Count Value .
<b>4</b> 0143	008E	Range Hi Ideal Pt385	Pt 100Ω (α=1.3850) Ideal A/D Count Value .
40143	0000	Range Lo	Pt 100Ω (α=1.3850)
<b>4</b> 0144	008F	Ideal Pt391	Ideal A/D Count Value .
<b>4</b> 0144	0001	Range Hi	$Pt\ 100\Omega\ (\alpha=1.3911)$
<b>4</b> 0145	0090	Ideal Pt391	Ideal A/D Count Value .
10110		Range Lo	Pt 100Ω ( $\alpha$ =1.3911)
<b>4</b> 0146	0091	ldeal Ni 120Ω	Ideal A/D Count Value .
		Range Hi	Ni 120Ω (α=1.6720)
<b>4</b> 0147	0092	ldeal Ni 120Ω	Ideal A/D Count Value .
		Range Lo	Ni 120Ω (α=1.6720)
<b>4</b> 0148	0093	ldeal Cu 10Ω	Ideal A/D Count Value .
		Range Hi	Cu 10Ω (α=1.4272)
<b>4</b> 0149	0094	ldeal Cu 10Ω	Ideal A/D Count Value .
		Range Lo	Cu 10Ω (α=1.4272)
<b>4</b> 0150	0095	ldeal 0-500Ω	Ideal A/D Count Value .
		Range Hi	Resistance 0-500Ω
<b>4</b> 0151	0096	Ideal 0-500Ω	Ideal A/D Count Value .
		Range Lo	Resistance 0-500Ω
<b>4</b> 0152	0097	Reserved	Do Not Use
<b>4</b> 0153	0098	Reserved	Do Not Use
<b>4</b> 0154	0099	Reserved	Do Not Use
<b>4</b> 0155	009A	Reserved	Do Not Use
<b>4</b> 0156	009B	Reserved	Do Not Use

## Model 966EN-4004 Model 966EN-4006

## Model 966EN-4004 Model 966EN-4006

Shaded 4xxxx register entries are Read-Only.

Ref	Addr.	Description	Data Type/Format
Holding	Holding Registers (4x References, Read/Write)		
<b>4</b> 0157	009C	Reserved	Do Not Use
<b>4</b> 0158	009D	Reserved	Do Not Use
<b>4</b> 0159	009E	Reserved	Do Not Use
<b>4</b> 0160	009F	Reserved	Do Not Use
<b>4</b> 0161	00A0	Reserved	Do Not Use
<b>4</b> 0162	00A1	Span Cal Register	A 16-Bit value whose bit position when set indicates the channel to be calibrated for span. For example: to calibrate span of channel 0, write 0001H to this register. To calibrate span of channel 11, write 0800H to this register.  IMPORTANT: You must FIRST write 5E2AH into the Calibration Access Register (Register 40021) before attempting calibration.
<b>4</b> 0163	00A2	Zero Cal Register	A 16-Bit value whose bit position when set indicates the channel to be calibrated for zero. For example: to calibrate zero of channel 0, write 0001H to this register. To calibrate zero of channel 11, write 0800H to this register.  IMPORTANT: You must FIRST write 5E2AH into the Calibration Access Register (Register 40021) before attempting calibration.
<b>4</b> 3001		This block Mirrors 3xxxx Registers.	Refer to Register Mirroring. 3xxxx Input Registers are mapped to the 43xxx Holding Register space using an address offset of 43000.

## Notes (Memory Map):

RTD input values are represented via 16-bit signed integer values with a resolution of  $0.1^{\circ}\text{C/lsb}$  and a possible range of  $-3276.8^{\circ}\text{C}$  to  $+3276.7^{\circ}\text{C}$ . The  $0\text{-}500\Omega$  input range values are represented via a 16-bit signed integer count, with  $0\Omega$  represented by a count of 0,  $250\Omega$  by a count of 16000, and  $500\Omega$  by a count of 32000 (resolution is  $1/64\Omega$  and the full range is 0 to 32767 decimal). Note that with 16-bit signed integers, a count of 0-7FFFH is a positive number, while 8000-FFFFH is a negative number.

These DIN-rail mount, industrial Ethernet, analog input modules will condition up to four or six RTD input signals according to the model, and provide an isolated 10/100BaseT Ethernet port for monitoring/control. Units are DC-powered and include reverse polarity protection. Inputs (as a group), network, and power are isolated from each other. Non-volatile reprogrammable module memory stores configuration & calibration info.

The BusWorks model prefix "900" denotes the Series 900 network I/O family. The "EN" suffix denotes EtherNet. Select 966EN for RTD inputs. The four digit suffix of this model number represents the following options, respectively: "4" = Ethernet; "0" = Default; "04" or "06" = 4 or 6 Channels.

Four or six RTD input channels according to model number. The unit must be wired and configured for the intended input type and range (see Connections section for details). The following paragraphs summarize this model's input types, ranges, and applicable specifications.

RTD: User configured to one of four RTD types, or as a simple resistance input as noted in Table 1 of the following page. The module supports 2 or 3-wire connection types and provides sensor excitation, linearization, lead-wire compensation (3-wire mode), & sensor lead break detection.

Input Reference Test Conditions (Unless Otherwise Noted): Pt RTD 0°C to 100°C, Ni RTD 0°C to 50°C, Cu RTD 0°C to 250°C; Ambient =  $25^{\circ}$ C; Power = 24VDC.

**Input Configuration:** Two-wire or three-wire only. **Excitation Current:** 1mA DC typical, all types. **Linearization:** Better than ±0.25°C, typical.

**Lead-Wire Compensation:** Applies to 3-wire RTD with lead wires of equal size and length. The maximum possible resistance including lead wires is  $506\Omega$ . Thus, the maximum lead resistance is approximately  $25\Omega$  per lead (Pt),  $15\Omega$  per lead (Ni),  $10\Omega$  per lead (Cu),  $3\Omega$  per lead ( $500\Omega$  resistance).

**Lead Resistance Effect:**  $3.5^{\circ}\text{C}$  per  $\Omega$  of unbalance typical for Pt,  $1.4^{\circ}\text{C}$  per  $\Omega$  of unbalance typical for Ni,  $25.5^{\circ}\text{C}$  per  $\Omega$  of unbalance typical for Cu.

**Break Detection**: Can provide upscale or downscale indication for all channels upon sensor failure (open) or lead breakage. This applies to faults with individual leads, or all leads together.

**IMPORTANT (0-500 ohm inputs w/ break detection):** The maximum input resistance including lead wires is about  $506\Omega$ . If break detection is set downscale and your input resistance is greater than  $506\Omega$  (saturated), this will trigger break detection and the input reading will be sent downscale for the over-range input resistance, without actual lead breakage. Likewise, upscale break is indistinguishable from an over-range input resistance greater than  $506\Omega$ .

Table 1: Supported RTD Types, Ranges, and Accuracy

RTD Type	α alpha	°C Range	Accuracy (Typ)
Pt 100Ω	1.3850	-200 to +850°C	±0.25°C
Pt 100Ω	1.3911	-200 to +850°C	±0.25°C
Ni 120Ω	1.6720	- 80 to +320°C	±0.25°C
Cu 10Ω	1.4272	-200 to +260°C	±1.25°C
Resistance (Linear)	1.000	0 to $500\Omega$	$\pm 0.05\Omega$

## **SPECIFICATIONS**

Model Numbers 966EN-4006 (6 RTD Inp) 966EN-4004 (4 RTD Inp)

## **Analog Inputs**

## **Analog Inputs**

**Note (Table 2):** Alpha ( $\alpha$ ) is used to identify the particular RTD curve. The value of alpha is derived by dividing the resistance of the sensor at 100°C by the resistance at 0°C ( $\alpha = R_{100^{\circ}\text{C}}/R_{0^{\circ}\text{C}}$ ). For Pt 100 $\Omega$ , this is 138.5 $\Omega$ /100.0 $\Omega$ , or 1.385 (also shown as 0.00385 $\Omega$ / $\Omega$ /°C).

Note that all channels share the same break detect configuration, but the input range may vary between channel pairs.

### **General Specifications**

**Accuracy:** Accuracy is better than  $\pm 0.1\%$  of span, typical for nominal input ranges. This includes the effects of repeatability, terminal point conformity, and linearization, but does not include sensor error.

Measurement Temperature Drift: Better than  $\pm 50$ ppm/°C ( $\pm 0.005$ %/°C). Analog to Digital Converter (A/D): A 16-bit  $\Sigma$ - $\Delta$  converter, Analog Devices AD7714YRU. A/D reference is  $1020\Omega$  (1.02V at 1mA excitation). The differential input is sampled ratiometric to the reference.

Input Bias Current: 1mA DC excitation current.

Resolution: 0.005% or 1 part in 20000 (see Table 2 below).

Table 2: Effective Resolution Per Applicable Range

Range	Resolution
10Ω Cu (α=1.4272)	0.2°C (0.36°F)
Pt (α=1.3850)	0.1°C (0.18°F)
Pt (α=1.3911)	0.1°C (0.18°F)
Ni (α=1.6720)	0.1°C (0.18°F)
$0$ to $500\Omega$	15.625mΩ

**Input Conversion Rate:** 80ms per channel, or 480ms for all six input channels.

**Input Filter:** Normal mode filtering, plus digital filtering optimized and fixed per input range within the  $\Sigma$ - $\Delta$  ADC.

Input Filter Bandwidth: -3dB at 3Hz, typical.

**Noise Rejection (Normal Mode):** Better than 40dB @ 60Hz, typical with  $100\Omega$  input unbalance.

**Noise Rejection (Common Mode):** Better than 130dB @ 60Hz, typical with  $100\Omega$  input unbalance ( $10\Omega$  unbalance for Cu RTD).

**Data Types:** Count  $(0-500\Omega \text{ range})$  - A 16-bit signed integer value with  $0\Omega$  represented by a count of 0, 250Ω represented by a count of 16000, and  $500\Omega$  represented by a count of 32000 (resolution is  $1/64\Omega$ ). The full range is 0 to 32767 decimal. Temperature (RTD inputs) - A 16-bit signed integer value with resolution of  $0.1^{\circ}\text{C/lsb}$ . For example, a value of 12059 is equivalent to 1205.9°C, a value of -187 equals  $-18.7^{\circ}\text{C}$ . The maximum possible temperature range is  $-3276.8^{\circ}\text{C}$  to  $+3276.7^{\circ}\text{C}$ .

## **Enclosure & Physical**

**Dimensions:** 1.05 inches wide, 4.68 inches tall, 4.35 inches deep. Refer to the dimensions drawing at the front of this manual.

DIN Rail Mount: Type EN50022; "T" rail (35mm).

**I/O Connectors:** Removable plug-in type terminal blocks rated for 15A/300V; AWG #12-24 stranded or solid copper wire.

Network Connector: 8-pin RJ-45 connector socket with metal shield (shield is bypassed to earth ground at the GND terminal via an isolation capacitor and TVS). Connections are wired MDI, as opposed to MDI-X. You must use a CAT-5 crossover cable to connect this module to a PC. Otherwise you may use an auto-crossing Ethernet switch, such as the Acromag 900EN-S005 to make connections.

RJ-45	Signal (MDI)	Description
1	Tx+	Transmit Positive
2	Tx-	Transmit Negative
3	Rx+	Receive Positive
4	Not Used	Connects to Pin 5
5	Not Used	Connects to Pin 4
6	Rx-	Receive Negative
7	Not Used	Connects to Pin 8
8	Not Used	Connects to Pin 7

**Case Material:** Self-extinguishing NYLON type 6.6 polyamide thermoplastic UL94 V-2, color beige; general purpose NEMA Type 1 enclosure.

Printed Circuit Boards: Military grade FR-4 epoxy glass.

Shipping Weight: 1 pound (0.45 Kg) packed.

Safety Approvals: : UL Listed (USA & Canada). Hazardous Locations-

Class I, Division 2, Groups A, B, C, D. Consult factory.

ATEX Certified: Assessment by TUV Rheinland of North of America, Inc.

per

ATEX Directive 94/9/EC.

Ex nA IIC T4 Gc

TUVNA 14 EX 0001X

x = Special Conditions

- 1) "WARNING-EXPLOSION HAZARD-DO NOT MAKE OR BREAK CONNECTIONS IN HAZARDOUS LOCATIONS OR AREAS"
- 2) "Warning: Must be installed in suitable enclosure with an Ingress Protection of IP54 minimum, in Hazardous Locations or Areas"

Operating Temperature:  $-25^{\circ}\text{C}$  to  $+70^{\circ}\text{C}$  (-13°F to +158°F). Storage Temperature:  $-40^{\circ}\text{C}$  to  $+85^{\circ}\text{C}$  (-40°F to +185°F).

Relative Humidity: 5 to 95%, non-condensing.

**Power Requirements:** 15-36V DC SELV (Safety Extra Low Voltage), 2.1W.

Observe proper polarity. See table for current.

Supply	966EN-4006/4004 Current Draw		
15V	114mA Typical, 125mA Maximum		
18V	95mA Typical, 105mA Maximum		
24V	73mA Typical, 80mA Maximum		
36V	54mA Typical, 59mA Maximum		

**CAUTION:** Risk of Electric Shock – More than one disconnect switch may be required to de-energize equipment before servicing.

Isolation: Input channels (as a group), power, and network circuits are isolated from each other for common-mode voltages up to 250VAC, or 354V DC off DC power ground, on a continuous basis (will withstand 1500VAC dielectric strength test for one minute without breakdown). Complies with test requirements of ANSI/ISA-82.01-1988 for voltage rating specified.

**Installation Category:** Designed to operate in an installation in a Pollution Degree 2 environment with an installation category (over-voltage category) II rating.

**Agency Approvals** 

#### **Environmental**

**CAUTION:** Do not exceed 36VDC peak, to avoid damage to the module.

External Fuse: Select a high surge tolerant fuse rated for 1A or less to protect unit.

Input channels are not isolated channel-to-channel, except for small common-mode voltage differences within ±4V.

These limits represent the minimum requirements of the standard, but product has typically been tested to comply with higher standards in some cases.

#### **Environmental**

## **EMC - CE Marked**

**Electromagnetic Interference Immunity (EMI):** Unit has demonstrated measurement shift less than  $\pm 0.25\%$  of input span with interference from switching solenoids, commutator motors, and drill motors.

## **Electromagnetic Compatibility (EMC)** -

## Immunity Per European Norm BS EN 61000-6-2:2005:

**Electrostatic Discharge (ESD) Immunity:** 4KV direct contact and 8KV air-discharge to the enclosure port per IEC61000-4-2.

**Radiated Field Immunity (RFI):** 10V/M, 80 to 1000MHz AM, 1.4 to 2GHz 3V/M, and 2 to 2.7GHz 1V/M, per IEC61000-4-3.

**Electrical Fast Transient Immunity (EFT):** 2KV to power, and 1KV to signal I/O per IEC61000-4-4.

Conducted RF Immunity (CRFI): 10V rms, 150KHz to 80MHz, per IEC61000-4-6.

Surge Immunity: 0.5KV per IEC61000-4-5.

#### Emissions Per European Norm BS EN 61000-6-4:2007

Radiated Frequency Emissions: 30 to 1000MHz per CISPR16 Class A Electromagnetic Compatibility (EMC): CE marked, per EMC Directive 2004/108/EC. Consult factory.

#### Immunity per BS EN 61000-6-2:

- 1) Electrostatic Discharge Immunity (ESD), per IEC 61000-4-2.
- 2) Radiated Field Immunity (RFI), per IEC 61000-4-3.
- 3) Electrical Fast Transient Immunity (EFT), per IEC 61000-4-4.
- 4) Surge Immunity, per IEC 61000-4-5.
- 5) Conducted RF Immunity (CRFI), per IEC 61000-4-6.

### Emissions per BS EN 61000-6-4:

- 1) Enclosure Port, per CISPR 16.
- 2) Low Voltage AC Mains Port, Per CISPR 16.
- 3) Telecom / Network Port, per CISPR 22.

**WARNING:** This is a Class A product. In a domestic environment, this product may cause radio interference in which the user may be required to take adequate measures.

**IMPORTANT:** Power, input, and output (I/O) wiring must be in accordance with Class I, Division 2 wiring methods of Article 501-4(b) of the National Electrical Code, NFPA 70 for installations in the US, or as specified in section 18-1J2 of the Canadian Electrical Code for installations within Canada and in accordance with the authority having jurisdiction.

This equipment is suitable for use in Class I, Division 2, Groups A, B, C, and D, or non-hazardous locations only.

**WARNING – EXPLOSION HAZARD –** Substitution of any components may impair suitability for Class I, Division 2.

**WARNING – EXPLOSION HAZARD –** Do not disconnect equipment unless power has been switched off or the area is known to be non-hazardous.

#### **Ethernet Interface**

**Connector:** Shielded RJ-45 socket, 8-pin, 10BaseT/100BaseTX. **Wiring:** Wired MDI. Unit does NOT support auto-crossover.

 $\begin{tabular}{ll} \textbf{Protocol:} & \textbf{Modbus TCP/IP w/Web Browser Configuration.} \end{tabular}$ 

**IP Address:** Default static IP address is 128.1.1.100. **Port:** Up to 10 sockets supported, uses port 502 (reserved for

Port: Up to 10 sockets supported, uses port 502 (reserved for Modbus).
Transient Protection: A Transient Voltage Suppressor (TVS) is applied differentially at transmit and receive channels. The metal shield is coupled to the earth ground terminal via an isolation capacitor and TVS.

**Data Rate:** Auto-sensed, 10Mbps or 100Mbps. **Duplex:** Auto-negotiated, Full or Half Duplex. **Compliance:** IEEE 802.3, 802.3u, 802.3x.

**Modbus TCP/IP Protocol Support:** Up to 10 sockets. Web pages for configuration/control are built-in and may be accessed over Ethernet via a standard web browser.

Rx/Tx Memory: 8K bytes SRAM (FIFO) for receive and transmit buffers.
Communication Distance: The distance between two devices on an Ethernet network is generally limited to 100 meters using recommended copper cable. Distances may be extended using hubs, switches, or fiber optic transmission. However, the total round trip delay time must not exceed 512 bit times for collision detection to work properly with CSMA/CD (half-duplex).

**Port Status Indicators:** Green LED indicates link status (ON if autonegotiation has successfully established a connection), yellow LED indicates activity (Ethernet connection is busy/traffic is present).

Address: The IP address can be preset by the user (static) and loaded from internal non-volatile memory, or automatically acquired at startup via a network server using a BOOTP (Bootstrap Protocol), or DHCP (Dynamic Host Configuration Protocol). The unit also includes a default mode toggle switch to cause the module to assume a "known" fixed static IP address of 128.1.1.100 for troubleshooting purposes.

Refer to Acromag Application Note 8500-734 for instructions on how to change the IP address of your PC network interface card in order to talk to an Acromag module.

#### **LED Indicators:**

**RUN (Green) -** Constant ON if power is on. Continuous flashing ON/OFF indicates unit is in "wink" ID mode.

**ST (Yellow) –** Blinks ON/OFF in default communication mode. Stays ON if an input is out of range.

**LINK (Green) –** Indicates Ethernet *LINK* status (ON if auto-negotiation has successfully established a connection).

**ACT (Yellow)** – Indicates Ethernet *ACTivity* (Ethernet connection is busy/traffic is present).

#### Controls:

Reset/Default Address Switch: This momentary toggle switch is located on the front panel and is used to either reset the module (toggle right), or toggle the module into, or out of Default Communication Mode (toggle left). In Default Mode, the module assumes the fixed static IP address "128.1.1.100", a default subnet mask "255.255.255.0", a default username of "User", and a default password of "password00". This switch can also be used to restore the module to its initial factory configuration by holding this switch in its default position while powering up the unit (see "Getting Out Of Trouble" in the Troubleshooting section for more information).

The minimum cable required for full operation of this device is Category 5. The term "Category" refers to classifications of UTP (Unshielded Twisted Pair) and STP (Shielded Twisted Pair) cables. There are 3 main categories of cable – Category 3, Category 4, and Category 5. The differences in classification is found in their electrical performance and this is documented in the TIA/EIA 568-A standard.

This device is designed for use in harsh industrial environments. Acromag recommends the use of shielded cable when wiring to this device. Select STP (Shielded Twisted Pair) cable rather than UTP (Unshielded Twisted Pair). The use of shielded cable will help protect the data being transmitted

#### **Controls & Indicators**

## ACCESSORY CABLES

from harmful EMI (Electromagnetic Interference) and RFI (Radio Frequency Interference). It will also help to lower your radiated emissions by keeping the cable from emitting EMI and RFI.

There are two types of cable conductors: solid cable and stranded cable. Stranded cables are more flexible than solid cables. But since attenuation is higher for stranded cables than solid conductor cables, these are generally reserved for short runs and patch applications less than 6 meters.

Currently there are two types of shielding employed in Category 5 STP cable: single-shielded and double-shielded. Both of these cables have the same core and jacket as UTP cables, but also include a thin foil outer shield that covers all four twisted-wire pairs. Variations may include a drain wire that encircles the outer jacket. A double-shielded version adds an outer wire screen that surrounds the foil shield and also functions as a drain wire. The drain wire or wire screen typically makes contact at each end of the cable with the metal shield around special RJ45 plug connectors. This shield then makes contact with the metal shield of shielded RJ45 sockets. The socket shield may make direct contact with earth ground, or it may be capacitively coupled to earth ground. In the Acromag 9xxEN modules, it makes contact with earth ground via a high voltage capacitor and transient voltage suppressor.

In addition to separately isolating the shield, this helps to minimize radio frequency and electromagnetic interference, and has the added benefit of protection from ESD (Electro-Static Discharge).

Further, Acromag recommends the use of *enhanced* Category 5 cable (CAT-5e). This cable has all the characteristics of Category 5, but includes enhancements that help to minimize crosstalk. Category 5e cable has a greater number of turns-per-inch in its twisted pairs and its performance is also more suitable for applications that make use of all four wire pairs for simultaneous bidirectional data transmission (full-duplex). As such, it is rated for frequencies up to 200MHz, double the rate of Category 5. This cable is defined in TIA/EIA-568A-5 (Addendum 5).

## Patch Cable & Crossover Cable

Acromag offers the following cable accessories for use with this module:

<u>Cable Model 5035-355</u> – A yellow, 3 foot long, single-shielded Category 5e STP patch cable with drain wire and an RJ45 plug at both ends. Use this cable to connect an Acromag 9xxEN I/O module to the Acromag 900EN-S005 switch.

<u>Cable Model 5035-360</u> – A green, 5 foot long, single-shielded Category 5e STP crossover cable with a drain wire and an RJ45 plug at both ends. This cable performs the Ethernet crossover function and is used to connect a PC directly to an Acromag Series 9xxEN I/O module.

Note that you do not need to use a crossover cable to connect your PC to this module if the Acromag 900EN-S005 switch is used between the PC and module, as the switch is auto-crossing. However, you must use a crossover cable when directly connecting your PC to a Series 9xxEN I/O Module without the use of an auto-crossing switch or hub.

You may obtain cable in other lengths and colors as required for your application from other vendors. For example, shielded CAT-5e cable is available from the following vendors:

- L-com Connectivity Products, <u>www.L-com.com</u>
- Pro-Link, www.prolink-cables.com

For very noisy environments or in the presence of strong electrical fields, you can obtain double-shielded CAT-5e cable and shielded RJ45 plugs from the following vendors:

- L-com Connectivity Products, <u>www.L-com.com</u>, see cable model TFSC2004 and shielded plug T8P8CSR.
- Regal Electronics, <u>www.regalusa.com</u>, see shielded plug model 1003B-8P8CSR-C5.

Complete premium double-shielded Category 5e standard and crossover cables in variable lengths can be obtained from Lumberg at <a href="https://www.lumbergusa.com">www.lumbergusa.com</a> (refer to their etherMate line). For example, specify RJ45S-RJ45S-656/B/3M for a double-shielded, 3 meter straight cable. Specify RJ45S-RJ45S-656/BX/3M for a double-shielded, 3 meter crossover cable.

## **Revision History**

The following table shows the revision history for this document:

Release Date	Version	EGR/DOC	Description of Revision
21 JUN 12	F	TPH/KLK	Updated input over/under range specifications (ECN 12A011).
04 JAN 13	G	CAP/BNB	Added ATEX and updated CE specifications (ECN 12L019).
21 APR 14	Н	CAP/SRW	Update ATEX per latest standards (ECO 14D012).
09 JAN 2019	J	CAP/ARP	Update "WARNING - EXPLOSION HAZARD - Substitution of <u>any</u> components" per ul.